



LISTING REPORT

INTERTEK TESTING SERVICES NA INC.

Issued: 9-22-09

Revised: 5-6-11

REPORT NO. 3186781NYM-001

Standard for Manual Signaling Boxes for Fire Alarm Systems, ANSI/UL 38, 8th Edition

Advanced Fire Systems, Inc

100 South Street

Hopkinton, MA 01748 USA

Single Action Manual Pull Station, Model (s) AX-APS2-F1 (-NYC denotes New York City)

Dual Action Manual Pull Station, Model (s) AX-APS2-F2 (-NYC denotes New York City)

Note:

1. Intertek verified that the force required to activate controls of referenced pull stations is not greater than 5 pounds of force (the measured force was 3.75 LB);
2. Intertek verified that pull station is operable with one hand;
3. Intertek verified that the manual action does not require tight grasping, pinching or twisting of the wrist.