

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-1713:0107

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: ADVANCED FIRE SYSTEMS, INC. 100 South Street, Hopkinton, MA 01748
Contact: Leigh Kaiser (508) 453-9995 Fax (508) 453-9996
Email: lekaiser@advancedco.com

DESIGN: Model 58000-750ADV multisensor photoelectric smoke detector. Unit employs a supplemental integral thermistor type heat sensor for use only as a supplement to the smoke detector. This thermal circuitry is NOT approved for use in lieu of required heat detectors. This device can be set at the control panel to any 5 modes of operation as detailed below. Refer to listee's data sheet for additional detailed product description and operational considerations.

- Mode 1 = High smoke sensitivity and high supplementary response to heat
- Mode 2 = High smoke sensitivity but no response to heat
- Mode 3 = Moderate smoke sensitivity with response to heat
- Mode 4 = Low smoke sensitivity with high response to heat
- Mode 5 = Fixed temperature heat detector rated 135°F (no smoke response)

RATING: 17 to 28 VDC, 5 to 9 V protocol

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as an analog photoelectric smoke detector for use with listee's separately listed compatible fire alarm control units and listed Models 45681 Series detector bases (CSFM Listing No. 7300-1713:103). Refer to listee's Installation Instruction Manual for details.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

XLF: 7272-1394:0117

07-14-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division